

BM TRADA

Results of Test : Chilt/RF13217/AR1

Carina and Alex Conyngham
Rock Farm
Fennor
Slane
Co Meath
Ireland

This document confirms that a fire resistance test was conducted in accordance with BSEN 1365-1: 1999 on a loadbearing compressed straw wall system on 25 October 2013 and the following results were achieved.

Integrity	
Cotton pad	135 (one hundred and thirty five) minutes*
Continuous flaming	135 (one hundred and thirty five) minutes*
Gap gauges	135 (one hundred and thirty five) minutes*
Insulation	
Average set	135 (one hundred and thirty five) minutes*
Standard set (maximum)	135 (one hundred and thirty five) minutes*


* No failure of the test criteria had occurred at termination of the test at 135 minutes

The results relate only to the specimens tested, as detailed in test report number Chilt/RF13217/AR1. This document is only valid in conjunction with the full test report.

The details of the sponsor of results of test certificate Chilt/RF13217 are held on file by Chiltern International Fire Ltd. This certificate is additional to that issued as Chilt/RF13217 and dated 17 March 2013. The original certificate shall remain valid and is not replaced by the additional certificate.



Robert Axe
Deputy Head of Section
Date:



Vincent Kerrigan
Technical Manager
Date:

18-03-2014

BM TRADA

Chiltern House, Stocking Lane, Hughenden Valley,
High Wycombe, HP14 4ND, United Kingdom
Tel: 01494 569800
Fax: 01494 564895
Web: www.bmtradagroup.com
Email: testing@bmtrada.com

This document is confidential and remains the property of BM TRADA

